

Serial - 8

Photos copy of Noc for drinking water of school. Original copy is attached in Pooja's office record.

47
27/7/2021

MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works Sector 39

TEST REPORT
Not for circulation

Ref. No. & Date :- No. GMSSS Sarangpur/2020-21/441 Dated 16.07.2021

Issued to :- The Principal
Govt. Model Sr. Sec. School,
Sarangpur, Chandigarh

Quantity of sample :- Approximate 1200 ml.

Date of Collection :- 19.07.2021

Client reference :- Sample collected by Laboratory Staff

Packing of sample :- Sample filled in P.P. and Glass Bottle.


Source of sample :- from School Tap of Govt. Model Sr. Sec. School,
Sarangpur, Chandigarh.


S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.7
2.	pH	7.0-8.5	----	7.53
3.	Residual Chlorine	0.2 - 0.4	mg/l.	0.1
4.	Total Alkalinity (as CaCO ₃)	200	-do-	260
5.	Total Hardness (as CaCO ₃)	200	-do-	126
6.	Chlorides (as Cl)	200	-do-	09
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	290
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide Receipt No.07/2021-22/032432, dated 19.07.2021. Amount Rs.3300/-


Note: Water is fit for drinking.


Lab. No. MCPHL/21/ 3064
Dated: - 22.07.2021


Chemist,
MCPHL Laboratory,
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No. 2,
Chandigarh
Dated: - 22/7/21

Endst No. MCPHL/21/_____
Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh with reference to your letter Endst. No.MOH/Supdt. Adm. 2021/6213 Dated 07.07.2021.


Chemist
MCPHL Laboratory,
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No. 2,
Chandigarh